

CONSTRUCTION NOTES

NOTE TO CLIENT/CONTRACTOR

BOUNDARY, POSITIONS OF DRAINS & THEIR DEPTH, & ALL DIMENSIONS ARE TO BE VERIFIED ON SITE BY THE BUILDER PRIOR TO COMMENCING WORK. NO WORK IS TO BE CARRIED OUT OVER THE BOUNDARY OF THE SITE WITHOUT THE WRITTEN CONSENT OF THE ADJOINING OWNER. ALL ELECTRICAL, HEATING & PLUMBING ARRANGEMENTS ARE TO SATISFY THEIR RELEVANT ALL STRUCTURAL AND EXPOSED TIMBERS ARE TO BE PRESSURE TREATED AGAINST INFESTATION & ROT, TO BE TANALISED OR EQUAL SYSTEM

ENSURE ALL EXCAVATED GROUND AROUND BUILDING MAINTAINS A FALL WAY FROM BUILDING FOR FLOW OF SURFACE WATER. IF THIS IS NOT POSSIBLE THEN SURFACE ACO DRAINS OR SIMILAR SHOULD BE USED TO DRAIN LOWERED AREAS AND CONNECT TO PROPOSED RAINWATER DRAINAGE SYSTEM.

EXTERNAL WALLS

102.5mm BRICK/100mm 100mm MIN. CAVITY, 100mm AIRCRETE BLOCK ABOVE DPC (STRUCTURAL ENGINEER TO ADVISE

12.5mm PLASTERBOARD ON DABS + SKIM COAT. SOLID AUSTENITIC STAINLESS STEEL TWIST TYPE WALL TIES TO B.S.1243 SPACED @ 750mm HORIZONTALLY, 450mm VERTICALLY AND 300mm VERTICALLY AT JAMBS TO ALL OPENINGS IN CAVITY WALLS. KNAUF INSULATION CROWN DRITHERM CAVITY SLAB 34 SUPER, 100mm THICK TO FILL CAVITY. WALL "U" VALUE 0.23 W/m2K AS STATED BY KNAUF INSULATION

SEMI-ENGINEERING QUALITY BRICKWORK BELOW HORIZONTAL D.P.C. BITUMEN HORIZONTAL D.P.C TO B.S. 743. TO BE MIN. 150mm ABOVE FINISHED EXTERNAL I FAN MIX CONCRETE CAVITY FILL FINISHED TO MINIMUM 225mm BELOW HORIZONTAL D.P.C. CONCRETE TRENCHFILL FOUNDATIONS, 600mm MIN. WIDE, UNDERSIDE OF FOUNDATION TO FINISHED GROUND LEVEL TO BE 1000mm OR DEEPER AS APPROVED BY L.A. BUILDING CONTROL OFFICER , TOP OF FOUNDATION TO BE FINISHED LEVEL

APPROX. 150mm BELOW GROUND LEVEL. FORM WEEPHOLES IN PERPENDS, 75mm HIGH AT THE BASE OF CAVITY TRAYS AND OVER

EXTERNAL OPENINGS, @ APPROX. 900mm C/5 (INCLUDING PERISCOPE VENTS).
THERMABATE COMBINED DPC/ INSULATED CAVITY CLOSERS TO ALL JAMBS AND SILLS TO EXTERNAL OPENINGS (OR SIMILAR APPROVED)

OPENINGS IN EXTERNALWALLS

CATNIC LINTELS TO HAVE MIN. 150mm END BEARINGS. INFILL VOID SPACE OF LINTELS WITH RIGID XTRATHERM INSULATION.(UNLESS PRE-INSULATED) SPECIFICATION TO SUIT WALL TYPE, WIDTH & LOADING NOTE WHEREVER DOUBLE JOISTS, DOUBLE RAFTERS, DOUBLE TRUSSED RAFTERS OR GIRDER TRUSSES BEAR DIRECTLY ONTOP OF LINTELS, 100x65mm PRECAST CONCRETE LINTELS 900mm LONG TO BE INSTALLED BETWEEN TIMBER AND LINTEL

LATERAL SUPPORT TO EXTERNAL WALLS

EXTERNAL WALLS PARALLEL TO FIRST FLOOR JOISTS, CEILING JOISTS AT GROUND OR FIRST FLOOR LEVEL AS APPLICABLE. RAFTERS/TRUSSED RAFTERS TO HAVE 30 x 5mm GALVANISED MILD STEEL STRAPS BUILT INTO INNER SKIN @ MAX. 1800mm C/S., FIXED BACK TO FIRST 3 No. TIMBERS. IN EACH CASE WITH 100 x 50mm S.W. SOLID BLOCKING PIECES INBETWEEN JOISTS OR RAFTERS

EXTERNALJOINERY & WINDOWS

ALL WINDOWS AND EXTERNAL JOINERY OWHITE UPVC FRAMED, TOP OR SIDE HUNG CASEMENT AS SHOWN, OPENING AREA TO BE GREATER THAN 1/20TH ROOM FLOOR AREA, SOME PART OF OPENING TO BE AT

ALL NEW WINDOWS TO ACHEIVE A MAXIMUM U VALUE 1.2Wm2K (MAXIMUM) NEW WINDOWS TO HABITABLE ROOMS AT FIRST FLOOR TO HAVE MINIUMUM UNOBSTRUCTED OPENING OF 450W x 750H WITH CILL BETWEEN 800 AND 1100mm

GLAZING SPECIFICATION (AS A MINIMUM). DOUBLE GLAZED OPTIONS: 28mm COATED CLEAR GLASS.

TO ACHEIVE U VALUE OF AT LEAST 1.2 W/M2k

SAFETYGLAZING

SAFETY GLAZING TO BE PROVIDED TO ALL PANES OF GLASS WITH A FACE AREA IN A WINDOW WITHIN 800mm OF FLOOR LEVEL, AND TO ALL GLAZED DOORS AND SIDE LIGHTS WHERE A PANE FACE AREA IS WITHIN 1500mm OF FLOOR LEVEL

NEWCONCRETEFLOOR

SEE INSULATION DETAIL SHEET FOR FLOOR BUIL UP AND U VALUES. FLOOR INSULATION TAKEN AROUND PERIMETER OF FLOOR SLAB AGAINST INSIDE FACE OF WALLS.

ALL NEW HABITABLE ROOMS TO HAVE BACKGROUND VENTILATION PROVIDED BY MIN. OF 8000mm2 OF FREE VENTILATION AREA

BATHROOM OR W.C. VENTILATION OPENING WINDOW/ROOFLIGHT FOR RAPID VENTILATION. TRICKLE VENT OPENING OF 8000mm2 FOR BACKGROUND VENTILATION.
MECHANICAL EXTRACT VENTILATION OF 15 LITRES/SEC WITH 15 MINUTES OVERRUN, OPPERATED BY LIGHT SWITCH. KITCHEN VENTILATION

OPENING WINDOW/ROOFLIGHT/DOOR FOR RAPID VENTILATION. TRICKLE VENT OPENING OF 8000mm2 FOR BACKGROUND VENTILATION.
MECHANICAL EXTRACT VENTILATION TO PROVIDE MINIMUM EXTRACTION OF 60 LITRES/SECOND DIRECT TO EXTERNAL AIR. UTILITY VENTILATION

OPENING DOOR FOR RAPID VENTILATION. MECHANICAL EXTRACT VENTILATION TO PROVIDE MINIMUM EXTRACTION OF 30 LITRES/SECOND DIRECT TO EXTERNAL AIR. OPERATED INTERMITTENTLY

HORIZONTAL CEILINGS:

12.5 mm GYPSUM PLASTERBOARD TO B.S. 1230:1970, TO UNDERSIDE OF METAL FRAME SYSTEM WITH PLASTER SKIM FINISH. ALL FIXINGS AND JOINTS TO BE IN ACCORDANCE WITH BRITISH GYPSUMS RECOMMENDATIONS.

SLOPING CEILINGS TO FIRST FLOOR

65mm KNAUF PIR INSULATED PLASTERBOARD, TO UNDERSIDE OF RAFTERS OR RAFTERS WITH PLASTER SKIM FINISH. 75 x 50mm TANALISED S.W. CROSS NOGGINS BETWEEN CEILING JOISTS OR RAFTERS AT JOINTS IN PLASTERBOARD. ALL FIXINGS AND JOINTS TO BE IN ACCORDANCE WITH BRITISH GYPSUMS

INTERNAL PARTITION WALLS (IF NOT USING LIGHTWEIGHTBLOCK) 15mm THICK DB CHECK/SOUNDBLOC PLASTERBOARD AND SKIM COAT TO BOTH SIDES

OF 98 x 38mm SW TIMBER STUDS, TO COMPLY WITH APPROVED DOC. E, E2 INTERNAL WALL TYPE B. ALL VOIDS TO BE INSULATED WITH 50mm THICK ROCKWOOL TO ACHIEVE Rw 40DB. MOISTURE RESISTANT PLASTERBOARD TO BE USED TO BATHROOM, KITCHEN AND WC WALLS, ADDITIONAL LAYER OF TILEBACKER BOARD WHERE WALLS TILED FROM TOP

LEAD FLASHING

WHERE SHOWN RAKE OUT MORTAR JOINT 40mm, 150mm ABOVE FINISHED ROOF LEVEL, CODE No. 4 LEAD FLASHING. GENERALLY LEAD FLASHING TO ALL ROOF ABUTMENTS TO HAVE CAVITY TRAY/STEPPED CAVITY TRAY ABOVE LEAD FLASHING. PROPRIETRY WEEPS TO EXPEL WATER ABOVE LEAD

STORMWATER DRAINAGE

NEW SURFACE WATER DRAINS ARE TO BE CONNECTED TO 100mm DRAINS TO DRAIN AS SPECIFIED IN THE WATER MANAGEMENT STATEMENT

PLUMBING WASTES

33mm DIAM. (OR 40mm IF WASTE GREATER THAN 1.7m BUT LESS THAN 3m LONG) WASTE FROM WASH HAND BASINS, 100mm/m MIN. FALL. 40mm DIAM (OR 50mm IF WASTE GREATER THAN 3m BUT LESS THAN 4m LONG) WASTES FROM SINKS, BATHS, BIDETS AND SHOWER TRAYS, 18-90 mm/m FALL 100mm DIAM. WASTE FROM W.C'S. 18mm/m MIN. FALL. ALL WASTES TO BE IN P.V.C., TO HAVE 75mm MIN. DEEP SEAL TRAPS, WITH SEPARATE CONNECTIONS TO S.V.P.

SMOKE/HEATDETECTION

SELF CONTAINED, MAINS OPERATED SMOKE/HEAT ALARMS TO CIRCULATION AREAS on ground and first floor. See plan. Alarms to be interlinked and PERMANENTLY WIRED TO A SEPARATLEY FUSED CIRCUIT AT THE MAINS DISTRIBUTION BOARD, IN ACCORDANCE WITH BS 5839 PART 6.

ELECTRICALWORK

ALL NEW ELECTRICAL WORK IS TO BE DESIGNED, INSTALLED, INSPECTED AND TESTED IN ACCORDANCE WITH BS 7617 (I.E.E WIRING REGULATIONS CURRENT EDITION). THE WORKS ARE TO BE UNDERTAKEN BY AN INSTALLER REGISTERED UNDER A SUITABLE ELECTRICAL SELF-CERTIFICATION SCHEME, OR ALTERNATIVELY BY A SUITABLY QUALIFIED PERSON, WITH A CERTIFICATE OF COMPLIANCE PRODUCED BY THAT PERSON TO BUILDING CONTROL

ON COMPLETION OF THE WORKS NEW LIGHTING. 100% ENERGY EFFICIENCY LIGHTING THROUGHOUT

STRUCTURAL STEELWORK/TIMBER

ALL BEAMS TO STRUCTURAL ENGINEERS DETAILS AND CALCULATIONS. PROVIDE MINIMUM 30 MINUTES FIRE RESISTANCE BY ENCASING STEEL BEAMS 15mm GYPSUM FIRELINE BOARD/ PROPRIETARY FIRE ENCASING SYSTEM. STRUCTURAL TIMBER TO BE COATED WITH CLEAR FR INTUMESCENT COATING



TWO STOREY EXTENSION TO 3, OLD TURNPIKE ROAD, CROWLE

MR & MRS McKEEVER

Drawing Title PROPOSED PLANS

13/05/2021 1:50 @ A1

p2021_013/02

All dimensions to be checked and verified on site.

Drawings to be read in conjunction with structural engineers/specialists drawings & calculations where applicable.

Drawings are not to be copied without the written consent of Insideout architecture + interiors ltd. 30 Stonebow Road Drakes Broughton Worcestershire WR10 2AP . 01905 841136 Registered 5382954

Please note: It is the responsibility of the Client to ascertain whether the Party Wall Act 1996 requires action on this project. Information can be found from the Department for Communities and Local Government at http://www.communities.gov.uk Insideout architecture + interiors Ltd accept no liability for conflicts arising from disputes of the Party Wall Act ect 1996.

www.insideout-ai.com